



**Coastal States
Energy Company**

A SUBSIDIARY OF THE COASTAL CORPORATION

The Energy People

0050

July 30, 1990

Mr. Harold Thompson
U.S. Environmental Protection Agency
Water Management Division (8WM-C)
1 Denver Place, Suite 500
999 - 18th Street
Denver, Colorado 80202-2413

Dear Mr. Thompson:

In accordance with the conditions of NPDES Discharge Permit UT-0023540, Part II - A-2 and Utah Mining Code Section 817.52(b)(i)(ii), Utah Fuel Company is herewith providing the required written notification of a failure to comply with the maximum effluent limitations for total dissolved solids at the 001 discharge point.

The problem occurred with the sample taken July 11, 1990, which had a TDS concentration of 852 mg/l. This concentration exceeds the 700 mg/l limitation established in the current NPDES discharge permit but does not exceed the 1000 mg/l limitation proposed in the draft copy of the renewal permit.

Sincerely,

Keith W. Welch

Keith W. Welch
Environmental Coordinator

KWW/ak/2400A

xc: Division of Oil, Gas & Mining
Division of Environmental Health
Glen A. Zumwalt
Keith Zobell

RECEIVED
JUL 31 1990

DIVISION OF
OIL, GAS & MINING